Form No : NTH/SL/F/5A



सत्यमेव जयते

# TEST CERTIFICATE



भारत सरकार उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय Government Of India Ministry Of Consumer Affairs , Food and Public Distribution राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)

## **National Test House**

ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091 Block - CP , Sector - V , Salt Lake City , Kolkata - 700 091 Phone No : 91-33-2367-3429 / 3430 / 3431 / 3871 / 9741 / 3308 , Fax No : 91-33-2367- 3871 / 3308 email : nthsal@wb.nic.in



#### भारत सरकार **Government Of India** राष्ट्रीय परीक्षण ज्ञाला (पूर्वी क्षेत्र) National Test House (Eastern Region) ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091. Block - CP, Sector -V, Salt Lake City, Kolkata - 700 091.



### परीक्षण प्रमाण पत्र TEST CERTIFICATE

ब्रमाण पत्र रहे.

जारी मोने का क्षित

क्रोड़ मां

पुष्ती की स

Test certificate no

Date of Issue

Code No

Page

No.of pages

NTH(ER)/CH(S)/2008/0015

26/02/2008

1203327536885

Issued to

SHREE SHYAM BEARINGS PVT. LTD.

Address

207, 2nd floor, 138, B.R.B. Basu Road, Kolkata-700001.

पाहक का संदर्भ सं.

Customer's Ref. No.

NIL2008-02-15

बिलाका स. एवं विसादक

Register No. & Date

0015/NTH(ER)/CH(S)/21/02/2008

परीक्षण सामग्री का निवरण :

Description of the test item

Fire Extinguishing Ball, Brand name "ELIDE FIRE"

परीक्षण सामग्री की पछवान :

Identification of the test item

The sample powder was packed in a spherical thermocol

ball

NA

परीक्षण सामग्री प्राप्ति वर्ग तिथि :

Date of reciept of the test

item

18/02/2008

व्यवहरा परीक्षण प्रणाली :

Method used for test

As per standard methods

नवुत्त प्रक्रिया असे प्रासांविक हो :

Sampling procedure where

relevant

Checked By

Debasish Saha Scientist-SC(Chemical) Approved By

Amal Kanti Chakrabarti Scentist-SD(Chemical)

Dr. Sudipta Ghoshray SO Chemical

Tested By



### भारत सरकार Government Of India राष्ट्रीय परीक्षण ज्ञात्ना (पूर्वी क्षेत्र) National Test House (Eastern Region)

ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091. Block - CP, Sector -V,Salt Lake City,Kolkata - 700 091.



## परीक्षण प्रमाण पत्र TEST CERTIFICATE

प्रमाण पच थी. तारा Test certificate no	নান না গৈছে Date of Issue	काङ स Code No	पुष्तर Page	yesi No. of
NTH(ER)/CH(S)/2008/0015	26/02/2008	1203327536885	2 2	4
Test Name		Test Result		
Appearance		Off white powder		
Lead (as Pb)		0.6 mg		
Arsenic (as As2O3)		Nii		
Cadmium (as Cd)		Ñii		
		12 W. W. W. V. V. V.		14 Car 15 18 18 18 18 18 18 18 18 18 18 18 18 18

Tested By

Chromium (as Cr)

Dr. Sudipta Ghoshray SO Chemical Checked By

0.2 mg/Kg

Debasish Saha Scientist-SC(Chemical) Approved By

Amal Kanti Chakrabarti Scentist-SD(Chemical)

पृष्की की स No. of pages



## भारत सरकार Government Of India राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र) National Test House (Eastern Region)

ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091. Block - CP, Sector -V,Salt Lake City,Kolkata - 700 091.



### परीक्षण प्रमाण पत्र TEST CERTIFICATE

90.12% (w/w)

असाम पंच र । वारा तान का कि		कोड स	dus.	
Test certificate no Date of Issue		Code No	Page	
NTH(ER)/CH(S)/2008/0015	26/02/2008	1203327536885	3	
Test Name		Test Result		
Mercury (as Hg )		Nil		
Nickel (as Ni)		0.3 mg/Kg		
Selenium (as Se)		Nil		

Tested By

Mono Ammonium Phosphate content

Dr. Sudipta Ghoshray SO Chemical

Debasish Saha Scientist-SC(Chemical) Approved By

Amal Kanti Chakrabarti Scentist-SD(Chemical)



#### भारत सरकार Government Of India राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र) National Test House (Eastern Region) -सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700

ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091. Block - CP, Sector -V,Salt Lake City,Kolkata - 700 091.



## परीक्षण प्रमाण पत्र TEST CERTIFICATE

अंगाण पच रहे.	सारा तोने का fais.	কাজ ল	पृत्रः	পুৰ্ব্ধা কৰি বা
Test certificate no	Date of Issue	Code No	Page	No.of pages
NTH(ER)/CH(S)/2008	8/0015 26/02/2008	1203327536885	4	

REMARKS:

No remarks can be offered for the tested sample.

Tested By

Dr. Sudipta Ghoshray SO Chemical

Debasish Saha Scientist-SC(Chemical)

Checked By

Approved By

Amal Kanti Chakrabarti Scentist-SD(Chemical)



### GOVERNMENT OF INDIA

MINISTRY OF CONSUMER AFFAIRS, FOOD & PUBLIC DISTRIBUTION DEPARTMENT OF CONSUMER AFFAIRS OFFICE OF THE DIRECTOR (ER) NATIONAL TEST HOUSE CP-BLOCK, SECTOR-V, SALT LAKE,

KOLKATA-700 091

\*\*\*\*\*\*\*

Telegraphic Address
" TEST HOUSE "
CALCUTTA

Telephone Nos. :2367 3429/3430/3431

DIRECT: (033)23673871

(033)

Fax No. +91-033-

24498026

E-mail : nthcal@wb.nic.in nther@wb.nic.in

Dt. 02.04.2008

NTH/ER/CH(s)/2008/0015 To M/S. Shree Shyam Bearings (P) Ltd. 138, B.R.B. Basu Road (Canning Street), 2<sup>nd</sup> floor, Room:No.207 Kolkata-700001

Sub: 'Remarks' on Test results for your sample of Elide-Fire-Fire Extinguishing ball.

Ref: i) Your letter No. Nil dt. 25.3.08

ii) Our Test Certificate of even No. dt. 26.2.2008.

Dear Sir,

With reference to above, please note that we have determined the chemical composition of your sample. Since, no standard specification is available for your product submitted, we did not make any remarks.

However, since the concentration of Toxic metals e.g. Arsenic, Mercury, Cadmium & Nickel are found Nil, except Lead, Chromium & Nickel in trace amount., it is certain that when exposed to fire, the product will not emanate toxic ingredients out of these metals, which may be harmful to the living things.

Also, the main constituent's concentration being more than 90% by mass which is Monoammonium Phosphate, the decomposition product of the same after exposure to fire should not contain any Pollutant as such.

So, the sample product sent to this Laboratory is opined to be free from toxic metals & generally safe to environment on the perspective from pollution.

Thanking you,

Yours faithfully

Scientist SC(Chemical), For Director, NTH(ER), Kolkata-91

pss/1